



September 5, 2025

Mayor and Council
Resort Village of Shields
8 Procter Drive
Shields, SK S7C 0A1

Dear Waterworks Owner/Operator:

RE: Rescinding of Precautionary Drinking Water Advisory

The Water Security Agency, in consultation with the Saskatchewan Health Authority-Saskatoon Office, are advising that the **"Precautionary Drinking Water Advisory" (PDWA)** issued by the Water Security Agency for the Resort Village of Shields' water distribution system (40-75 - Procter Drive only) on September 2, 2025 be rescinded immediately this Friday September 5, 2025.

The rescinding of the PDWA was based upon information provided by your community, which included:

- The repair has been completed, the water main has been flushed and disinfected
- Chlorine residuals throughout the distribution system are within regulatory requirements; and
- Bacteriological sampling is within regulatory limits.

Your community may return to normal monitoring requirements as identified in your permits monitoring schedule.

In closing, I would like to acknowledge that the Water Security Agency appreciates the efforts and cooperation demonstrated by staff at your waterworks system, as well as officials of the Resort Village of Shields in addressing the advisory.

Should you have any questions or concerns, please call me at (306) 230-3254.

Sincerely,

A handwritten signature in black ink, appearing to read "Lee Reinhart".

Lee Reinhart
Supervisor, Environment Officer
Water Security Agency – Science and Licensing Division

CC. Water Security Agency, Regina
Saskatchewan Health Authority-Saskatoon Office